

MPDH Sample Results: 2018 Q2 (April - June)

<u>Case/Sample ID</u>	<u>Project Name</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
427447	DPH-PB	1	4/10/18	< 1.00	ppb
427447	DPH-PB	1A	4/10/18	< 1.00	ppb
426422	DPH-PB	2	4/23/18	1.19	ppb
426422	DPH-PB	2A	4/23/18	< 1.00	ppb
427509	DPH-PB	3	5/7/18	4.89	ppb
427509	DPH-PB	3A	5/7/18	1.67	ppb
427649	DPH-PB	4	5/11/18	< 1.00	ppb
427649	DPH-PB	4A	5/11/18	< 1.00	ppb
428759	DPH-PB	5	5/22/18	< 1.00	ppb
428759	DPH-PB	5A	5/22/18	< 1.00	ppb
428764	DPH-PB	6	5/23/18	< 1.00	ppb
428764	DPH-PB	6A	5/23/18	< 1.00	ppb
428389	DPH-PB	7	6/1/18	< 1.00	ppb
428389	DPH-PB	7A	6/1/18	< 1.00	ppb
428686	DPH-PB	8	6/1/18	< 1.00	ppb
428686	DPH-PB	8A	6/1/18	< 1.00	ppb
428329	DPH-PB	9	6/5/18	< 1.00	ppb
428329	DPH-PB	9A	6/5/18	< 1.00	ppb
428796	DPH-PB	10	6/8/18	< 1.00	ppb
428796	DPH-PB	10A	6/8/18	< 1.00	ppb
429340	DPH-PB	11	6/18/18	2.50	ppb
429340	DPH-PB	11A	6/18/18	1.52	ppb
424012	DPH-PB	12	6/21/18	< 1.00	ppb
424012	DPH-PB	12A	6/21/18	< 1.00	ppb
429306	DPH-PB	13	6/22/18	< 1.00	ppb
429306	DPH-PB	13A	6/22/18	< 1.00	ppb
429417	DPH-PB	14	6/26/18	1.04	ppb
429417	DPH-PB	14A	6/26/18	< 1.00	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”