

Lead Request Sample Results: 2018 Q4 (October - December)

Data below show approved lead results from tests of drinking water in residential homes following a request from the local water department. No specific information is available on whether the home had a lead service lines or other risk for lead in the drinking water.

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
3997795	Medford	1	10/2/18	< 1.00	ppb
3997798	Medford	2	10/5/18	< 1.00	ppb
3999092	Marblehead	3	10/10/18	3.14	ppb
3997797	Medford	4	10/11/18	< 1.00	ppb
3997796	Medford	5	10/12/18	1.04	ppb
3999090	Medford	6	10/15/18	1.57	ppb
3999091	Medford	7	10/16/18	< 1.00	ppb
4006572	Medford	8	10/22/18	2.46	ppb
4006568	Medford	9	10/25/18	< 1.00	ppb
4006567	Medford	10	10/25/18	8.65	ppb
4006571	Medford	11	10/26/18	3.18	ppb
4006565	Medford	12	10/27/18	1.86	ppb
4006566	Medford	13	10/27/18	< 1.00	ppb
4006570	Medford	14	11/1/18	21.2*	ppb
4006570	Medford	14A	11/1/18	21.6*	ppb
4006569	Medford	15	11/1/18	1.79	ppb
4019988	Medford	16	11/24/18	< 1.00	ppb
4018484	Norwood	17	11/29/18	11.2	ppb
4026670	Medford	18	12/5/18	1.04	ppb
4026668	Medford	19	12/6/18	< 1.00	ppb
4023695	Framingham	20	12/9/18	< 1.00	ppb
4026669	Medford	21	12/9/18	< 1.00	ppb
4032471	Medford	22	12/17/18	1.65	ppb
4032470	Medford	23	12/26/18	< 1.00	ppb
4032472	Medford	24	12/26/18	2.07	ppb
4032466	Medford	25	12/27/18	6.28	ppb
4032467	Medford	26	12/27/18	< 1.00	ppb
4032468	Medford	27	12/28/18	13.2	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.

Lead Request Sample Results: 2018 Q4 (October - December)

Data below show approved lead results from tests of drinking water in residential homes following a request from the local water department. No specific information is available on whether the home had a lead service lines or other risk for lead in the drinking water.