

Lead Request Sample Results: 2019 Q1 (January - March)

Data below show approved lead results from tests of drinking water in residential homes following a request from the local water department. No specific information is available on whether the home had a lead service lines or other risk for lead in the drinking water.

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4037512	Medford	1	1/2/19	2.66	ppb
4037509	Medford	2	1/6/19	6.13	ppb
4037513	Medford	3	1/8/19	18.0*	ppb
4037513	Medford	3A	1/8/19	19.4*	ppb
4037510	Medford	4	1/9/19	< 1.00	ppb
4037511	Medford	5	1/10/19	10.2	ppb
4044812	Medford	6	1/14/19	4.28	ppb
4044813	Medford	7	1/15/19	1.28	ppb
4048982	Medford	8	1/28/19	< 1.00	ppb
4048981	Medford	9	1/30/19	1.51	ppb
4048983	Medford	10	1/31/19	1.50	ppb
4048980	Medford	11	2/3/19	< 1.00	ppb
4054491	Medford	12	2/9/19	3.78	ppb
4054492	Medford	13	2/12/19	2.27	ppb
4054493	Medford	14	2/14/19	14.6	ppb
4054493	Medford	14A	2/14/19	12.7	ppb
4054977	Medford	15	2/18/19	< 1.00	ppb
4060597	Medford	16	2/21/19	< 1.00	ppb
4060598	Medford	17	2/28/19	< 1.00	ppb
4062716	Medford	18	3/13/19	.625	ppb
4068100	Medford	20	3/19/19	2.06	ppb
4062719	Medford	21	3/23/19	20.6*	ppb

- **ppb** = parts per billion or µg/L
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.