

## Lead Service Line Sample Results: 2020 Q2 (April - June)

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4442627	Boston	1	4/1/21	16.8	ppb
4442662	Boston	2	4/3/21	11.1	ppb
4450062	Boston	3	4/20/21	0.143	ppb
4460898	Boston	4	5/11/21	13.0	ppb
4467982	Boston	5	5/21/21	31.1	ppb

- ppb = parts per billion or  $\mu\text{g/L}$
- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of 15 ppb.