

## Lead Request Sample Results: 2022 Q2 (April - June)

Data below show approved lead results from tests of drinking water in residential homes following a request from the local water department. No specific information is available on whether the home had a lead service lines or other risk for lead in the drinking water.

<u>Case/Sample ID</u>	<u>Town</u>	<u>Sample Address</u>	<u>Collection Date</u>	<u>Results</u>	<u>Units</u>
4629774	Medford	1	4/2/22	< 1.00	ppb
4629776	Medford	2	4/3/22	17.6*	ppb
4629775	Medford	3	4/4/22	9.64	ppb
4632865	Medford	4	4/6/22	4.42	ppb
4637271	Medford	5	4/11/22	1.89	ppb
4637270	Medford	6	4/12/22	5.52	ppb
4637272	Medford	7	4/12/22	< 1.00	ppb
4637273	Medford	8	4/19/22	3.05	ppb
4637275	Winthrop	9	4/20/22	1.87	ppb
4637274	Milton	10	4/21/22	1.64	ppb
4641691	Medford	11	4/21/22	1.27	ppb
4645048	Newton	12	4/28/22	1.36	ppb
4648546	Boston	13	5/10/22	3.11	ppb
4648547	Medford	14	5/10/22	1.73	ppb
4650920	Chelsea	15	5/11/22	< 1.00	ppb
4652012	Medford	16	5/11/22	14.6	ppb
4650921	Chelsea	17	5/12/22	< 1.00	ppb
4652013	Medford	18	5/13/22	1.22	ppb
4650922	Chelsea	19	5/13/22	< 1.00	ppb
4655835	Medford	20	5/20/22	< 1.00	ppb
4663014	Medford	21	6/2/22	1.62	ppb
4663013	Medford	22	6/2/22	9.01	ppb
4662054	Winthrop	23	6/6/22	11.6	ppb
4669134	Medford	24	6/17/22	< 1.00	ppb
4669133	Medford	25	6/18/22	7.83	ppb

• **ppb** = parts per billion or µg/L

## Lead Request Sample Results: 2022 Q2 (April - June)

Data below show approved lead results from tests of drinking water in residential homes following a request from the local water department. No specific information is available on whether the home had a lead service lines or other risk for lead in the drinking water.

- “<” means that the lead level in the sample was non-detectable at the indicated sensitivity of the instrument and analytical method. Can also be stated as “less than the detection limit.”
- Samples with the same sample number but different test numbers (e.g., “1” and “1A” refer to tests on an original sample and a follow-up duplicate test respectively). Samples may be tested twice to confirm the initial lead level if the first lead level detected is close to the lead Action Level of **15 ppb**.